



0 1/4" 1/2" 1" 2"

GRAPHIC SCALE: FOR REFERENCE ONLY



KEY NOTES

1. ALL EQUIPMENT SHOWN IS NEW UNLESS OTHERWISE NOTED.
2. MECHANICAL AND PLUMBING EQUIPMENT SHOWN ARE FOR REFERENCE ONLY. REFER TO MECHANICAL AND PLUMBING DRAWINGS FOR EXACT LOCATION OF ALL EQUIPMENT.
3. THE FIRE ALARM SYSTEM IS A CONTRACTOR DESIGN-BUILD SYSTEM. FIRE ALARM DEVICES SHOWN ARE FOR COORDINATION ONLY. CONTRACTOR SHALL PROVIDE HARDWARE, EQUIPMENT, DEVICES, ACCESSORIES AND ANY ADDITIONAL ITEMS REQUIRED FOR A COMPLETE AND OPERATIONAL CODE COMPLIANT SYSTEM. ALL CONDUIT ROUTING SIZING, CABLING, CALCULATION, ETC ARE ALSO CONTRACTOR DESIGN BUILD. REFER TO SPECIFICATION 284600 FOR ADDITIONAL INFORMATION.

1. PROVIDE DUPLEX RECEPTACLE FOR EACH TOWEL DISPENSER. LOCATE RECEPTACLE DIRECTLY ABOVE EACH DISPENSER BEHIND REMOVABLE WALL PANEL ABOVE MIRROR. PROVIDE CONDUIT IN WALL TO ROUTE CONNECTION TO DISPENSER.

1 TERMINAL - SECTOR E1 - T2TS40 - ENPLANING - FLOOR PLAN - ELECTRICAL
SCALE: 1/4" = 1'-0"

[illegible]

 Port of Portland	
 mwa architects	 PAE pae-engineers.com 151 SW 1st Avenue #300 Portland, OR 97204 503.226.2921 pae-engineers.com
2025D031 DESIGN NUMBER	103101 PROJECT NUMBER



PORTLAND INTERNATIONAL AIRPORT TERMINAL RESTROOM REHABILITATION 2026 TERMINAL - ENPLANING - SECTOR E1 - T2TS40 - FLOOR PLAN - ELECTRICAL	SUBMITTED BY		BRIAN FRANCIS	
	DESIGNED BY		A. NGUYEN	
	DRAWN BY		A. NGUYEN	
	CHECKED BY		J. MUTSCHLER	
	DATE		JULY 2026	
	SHEET NO.		139	TYPE CD
	DRAWING NO.		DISC. SHT. NO.	
PDX 2026-510		E3.08		