



CAN YOU SEE THE AIRPLANES? THE ADJACENT SAMPLES SHOW THREE DIFFERENT LEVELS OF SHADING. SETTINGS FOR VIEWING AND PRINTING DRAWING CONTENT ARE OPTIMIZED WHEN ALL THREE PLANES ARE VISIBLE. THIS GUIDANCE IS PROVIDED FOR REFERENCE ONLY.

E LIGHTING DIMMING RELAY CABINET 4LDC2T-15E-A											
CONTROL AREA			RELAY CONTROL INPUTS						CIRCUITING INFORMATION		KEYNOTES
RELAY	ZONE	DESCRIPTION	SENSOR	SWITCH /CONTROL STATION	PHOTOCELL	DIMMING/ HIGH-END TRIM	TIME CLOCK	EMERGENCY SOURCE	PANEL	LOAD (VA)	
1	Z2-32-01E	T2TD44 COMPANION CARE	OS	YES	NO	YES	NO	YES	E4L1T-17D	47	
2	Z2-32-02	T2TD44 COMPANION CARE	OS	YES	NO	YES	NO	NO	4L2T-15E	57	
3	Z2-31-03E	T2TC66 COMPANION CARE	OS	YES	NO	YES	NO	YES	E4L1T-17D	47	
4		RESTROOM ALL USER T2TD69						NO	4L2T-15E		
5	Z2-31-05	T2TC66 COMPANION CARE	OS	YES	NO	YES	NO	NO	4L2T-15E	57	
6		RESTROOM ALL USER T2TD69						NO	4L2T-15E		
7		SPARE									
8		RESTROOM ALL USER T2TD69						NO	4L2T-15E		
9		SPARE									
10		RESTROOM ENHANCED FAMILY T2TD44						NO	4L2T-15E		
11		SPARE									
12		RESTROOM ALL USER T2TC45						NO	4L2T-15E		
13		SPARE									
14		RESTROOM ALL USER T2TD45						NO	4L2T-15E		
15		SPARE									
16		CIRCULATION T2TC40						NO	4L2T-15E		
17		SPARE									
18		RESTROOM ALL USER T2TD45						NO	4L2T-15E		
19		SPARE									
20		LACTATION ROOM T2TD67						NO	4L2T-15E		
21		RESTROOM ALL USER T2TD69						YES	E4L3T-17E		
22		RESTROOM ALL USER T2TD69						NO	4L2T-15E		
23		RESTROOM ALL USER T2TD45						YES	E4L3T-17E		
24		RESTROOM ALL USER T2TD69						NO	4L2T-15E		
25		CIRCULATION T2TD60						NO	4L2T-15E		
26		RESTROOM ALL USER T2TD45						NO	4L2T-15E		
27		RESTROOM ALL USER T2TD69						NO	4L2T-15E		
28		CHECK IN - T2TH40						NO	4L2T-15E		
29		RESTROOM FAMILY T2TD66						NO	4L2T-15E		
30		CHECK IN - T2TH40						NO	4L2T-15E		
31		RESTROOM ALL USER T2TD69						NO	4L2T-15E		
32		SPARE									
33		RESTROOM FAMILY T2TD66						NO	4L2T-15E		
34		CONCESSION SEATING T2TC33						NO	4L2T-15E		
35		LACTATION ROOM - T2TD63						NO	4L2T-15E		
36		RESTROOM ALL USER - T2TD45						NO	4L2T-15E		
37		CIRCULATION T2TD40						NO	4L2T-15E		
38		LACTATION ROOM - T2TD43						NO	4L2T-15E		
39		CHECK IN - T2TH40						NO	4L2T-15E		
40		LACTATION ROOM - T2TD43						NO	4L2T-15E		
41		CHECK IN - T2TH40						NO	4L2T-15E		
42		RESTROOM ALL USER T2TD45						NO	4L2T-15E		
43		RESTROOM ALL USER T2TD69						NO	4L2T-15E		
44		RESTROOM ENHANCED FAMILY T2TD44						NO	4L2T-15E		
45		RESTROOM ALL USER T2TD69						NO	4L2T-15E		
46		RESTROOM ALL USER T2TD45						NO	4L2T-15E		
47		CHECK IN - T2TF49						NO	4L2T-15E		
48		CHECK IN - T2TF49						NO	4L2T-15E		

KEY NOTES

1. 48 ZONE RELAY PANEL IS EXISTING. MAINTAIN EXISTING CONNECTIONS AND PROVIDE NEW CONNECTIONS SHOWN.

pae-engineers.com

151 SW 1st Avenue #300
Portland, OR 97204

503.226.2921
pae-engineers.com

2025D031
DESIGN NUMBER

103101
PROJECT NUMBER

REGISTERED PROFESSIONAL
ENGINEER
44775PE

OREGON
JULY 13, 1999
GRANT R. PARTHEIMER

7-19-26
EXPIRES: 12/31/2026

PORTLAND INTERNATIONAL AIRPORT

TERMINAL RESTROOM REHABILITATION 2026

LIGHTING CONTROL SCHEDULE 4 - ELECTRICAL

SUBMITTED BY	BRIAN FRANCIS		
DESIGNED BY	A. NGUYEN		
DRAWN BY	A. NGUYEN		
CHECKED BY	J. MUTSCHLER		
DATE	JULY 2026		
SHEET NO.	149	TYPE	CD
DRAWING NO.	PDX 2026-510	DISC. SHT. NO.	E7.04